

NO.F.1(36)/HM/PHSS/KGT/VJ/2026/
Government of Tripura
Office of the Headmaster
Pabiacherra Class-XII School
Kumarghat, Unakoti Tripura

Dated, Kumarghat, the 08th May, 2026.

Notice Inviting Quotation

Quotations are hereby invited from bonafide firm/agencies for supply of **fire safety equipment** for Pabiacherra Class XII School, Kumarghat, Unakoti, Tripura as per enclosed **Advisory** issued by the Director of Fire and Emergency Services, Government of Tripura .

Quotation in sealed packet, are to be dropped in the sealed box kept in the office of the undersigned on all working days from the 11th May, 2026 to 18th May, 2026 during working hour.

The Quotation shall be opened on the 19th May, 2026 at 12.00 PM (if possible). The interested Bidders/their representatives may witness the whole process of selecting the eligible agency.

The Quotations should be dropped along with the following documents -

1. Copy of valid trade license.
2. Copy of GST clearance for the last quarter.
3. Copy of PAN card.

Terms & Condition -

1. Income Tax shall be deducted from the suppliers as per applicable rate.
2. GST shall be deducted as per applicable rate.
3. The Authority reserves the right to cancel the whole/ part of supply order without assigning any reason.
4. Bills are to be submitted in duplicate.
5. Payment shall be made by on receipt of articles in good condition.
6. Articles are to be supplied at the School and transportation cost to be borne by the supplier.

Encl: Referred Advisory.

SUBRATA PAL Digitally signed by
SUBRATA PAL
Date: 2026.05.08 12:59:34
+05'30'

Member Secretary
School Management Committee
Pabiacherra Class XII School
Kumarghat, Unakoti, Tripura



GOVERNMENT OF TRIPURA
**DIRECTORATE OF FIRE & EMERGENCY
SERVICES**
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSRTFES/2026/00069

Dated: 17/03/2026

To,
Subrata Pal
Kumarghat, Unakoti
Kumarghat S.O - 799264

Sub: **Fire Safety Recommendation** For Application Reference No **FSRTFES/2026/00069** .

With reference to your Application Reference No FSRTFES/2026/00069 Dated 26/02/2026 Fire Safety Recommendation on fire prevention and fire safety measures of the following building/premises is hereby issued in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules.

Name of the Applicant:	Subrata Pal			
Name of Owner with Plot details:	S. No.	Owner Name and Address		
	1.	ত্রিপুরা সরকারের পক্ষে শিক্ষা বিভাগ কর্তৃক রক্ষিত		
	S. No.	Plot No	Total Area	Classification
	1.	1489	0.52	----
	2.	1490	0.14	নাল
	3.	1491	1.03	নাল
	4.	1563	0.33	টিলা
	5.	2235	0.26	নাল
	6.	2321	0.41	নাল
7.	2322	0.2	নাল	
Name of the Property/ Organization/ Commercial establishment	Pabiacherra Class Xii School			
Address of the Building/ Premises:	Area Name Pabiacherra, Ward No.10, Kumarghat Municipal Council, Post Office Kumarghat S.O - 799264, Unakoti District, Tripura.			

A Fire Safety Certificate (FSC) will be issued, subject to verification of compliance of fire prevention and fire safety measures on which the fire safety recommendations enumerated in the attached letter and further submission of application through online system.

Director,
Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala

***** WE SERVE TO SAVE*****

This certificate shall not be used by the Insurance service provider

Fire Safety Advisory and Suggestion:

- 1.Road width measuring 08 meter to be required. (refer to TBR 2017)
- 2.Gate width measuring 10 meter to be required. (refer to TBR 2017)
- 3.Width of approach road measuring 10 meter to be required. (refer to TBR 2017)
- 4.02 Nos. staircases measuring 1.5 meter to be required in the school building (ground floor). (refer to TBR 2017)
- 5.02 Nos. staircases measuring 1.5 meter to be required in the school building (ground floor). (refer to TBR 2017)
- 6.02 Nos. Continuous staircase to terrace of the school building to be required free from obstruction. (refer to TBR 2017)
- 7.Width of corridor measuring 1.5 meter to be required in the school building (ground floor). (refer to TBR 2017)
- 8.Door size measuring 1.5 meter to be required in the school building. (refer to TBR 2017)
- 9.02 (Two) Nos. Co2 fire extinguisher capacity of 4.5 kg to be installed near electric main panel board in the ground floor of school building. (Refer to NBC 2016 Part-4)10.01 (One) No. Co2 fire extinguisher capacity of 2 kg to be installed at a distance of the 15-meter interval on ground floor of the school building. (Refer to NBC 2016 Part-4)11.01 (One) No. Co2 fire extinguisher capacity of 4.5 kg to be installed in each of the following location: Computer lab, Chemistry lab, Physics lab & Atal tinkering lab, in the school building. (Refer to NBC 2016 Part-4)
- 12.01 (One) No. ABC fire extinguisher having capacity of 6 kg to be installed at a distance of the 15-meter interval on ground floor of the school building block-1. (refer to NBC 2016 Part-4)13.01 (One) No. ABC fire extinguisher having capacity of 6 kg to be installed in each of the following location: Biology lab in the school building. (refer to NBC 2016 Part-4)
- 14.02 (Two) Nos. wet chemical fire extinguisher having capacity of 09 litre to be installed in the Mid-day-Meal kitchen room. (refer to NBC 2016 Part-4)
- 15.06 (Six) Nos. Sand bucket filled with dry sand under the rain shade hanging in the front side of the school building.
- 15.06 (Six) Nos. Sand bucket filled with dry sand under the rain shade hanging in the front side of the school building.
- 17.30-meter-long hose reel hose system to be installed in the building connected with down comer system. (refer to NBC 2016 Part-4)
- 18.Nozzle diameter 19 mm to be required. (refer to NBC 2016 Part-4)
- 19.Electric main panel board to be installed in the ground floor of school building.(refer to NBC 2016 Part-4)
- 20.02 Nos. hooter with battery back-up to be installed in the ground floor of the school building. (refer to NBC 2016 Part-4)21.02 Nos. MCP with battery back-up to be installed in the ground floor of the school building. (Refer to NBC 2016 Part-4)
- 22.Down comer system to be installed with mild steel pipe of thickness 4.6 mm and 100 mm dia. (refer to NBC 2016 Part-4)
- 23.Landing valves shall be provided in the school building according to the following floor-wise distribution: Two points on ground floor of the school building ,(refer to NBC 2016 Part-4)
- 24.Double door hose box with accessories such as delivery hose short branch etc. to be installed near the hose reel point in the school building with the following distribution: - Two points on ground floor of the school building. (refer to NBC 2016 Part-4)
- 25.Two-way fire inlet valve along with hydrant point to be provided in the front side of the school building. (refer to NBC 2016 Part-4)
- 26.Terrace level pump 450 LPM minimum discharge of 3.5 kg/ cm2 with connect with the terrace level tank along with accessories pressure gauge, pressure switch, air release valve & non returning valve to be installed at terrace of the school building. (refer to NBC 2016 Part-4)
- 27.Terrace level head of pump 70 meter to be required. (refer to NBC 2016 Part-4)
- 28.Terrace level power supply should be 03 (three) phase. (refer to NBC 2016 Part-4)
- 29.Terrace tank capacity of 10,000 liters to be constructed for exclusively firefighting purpose. (refer to NBC 2016 Part-4)
- 30.Trained person fire fighters should be engaged to operate the equipment's while in emergency and all emergency contact numbers such as fire, police station, ambulance, electricity supply should be displayed on a visible place in the School premises area. (refer to NBC 2016 Part-4)
- 31.To ensure the safety of all students and staff, any unused combustible materials must not be stored anywhere within the school building or on its immediate premises.

NB:-Issued

Digitally signed by MEGHA JAIN
Date:17-03-2026 17:49:19 PM